


IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

6.4.2.11.3	TABLE: - Change of operating mode – Normal to bypass mode - Overload test		P
------------	--	--	---

Description of test conditions / test construction:

- 1) UPS has a bypass mode of operation which is automatic in operation under conditions of output overload.
- 2) The input and output voltage waveforms shall be observed during transitions normal to bypass mode.

Measured graph: Load transfer from inverter to mains



Channel 1 - Input Voltage
Channel 2 - Output Voltage
Channel 3 - Input Current

IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

6.4.2.11.4 TABLE: - Step load –Normal mode


P

Description of test conditions / test construction:

- 1) Impact linear load as defined 20% => 100 %=> 20% nominal load with 230V/50Hz in normal mode.
- 2) Check the transient response


Measured graph:

- 1) Step load from 20% to 100% linear load



Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50 Hz	20% to 100% load	219.0	/	/	214.7	/	/	2.0%	/	/

- 2) Step load from 100% down to 20% linear load



Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50 Hz	100% to 20% load	219.6	/	/	220.6	/	/	2.0%	/	/

6.4.2.11.5 TABLE: - Step load – Stored energy mode

P


IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

Description of test conditions / test construction:

- 1) Impact linear load as defined 20% => 100 %=> 20% nominal load with 230V/50Hz in battery mode.
- 2) Check the transient response


Measured graph:

- 1) Step load from 20% to 100% linear load



Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50 Hz	20% to 100% load	220.1	/	/	214.1	/	/	2.7%	/	/

- 2) Step load from 100% down to 20% linear load



Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50 Hz	100% to 20% load	220.2	/	/	220.3	/	/	0.1%	/	/

6.4.3.1	TABLE: - Output – Non-linear load: Normal mode – Full load - Harmonic components measurement									P
---------	---	--	--	--	--	--	--	--	--	---

IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

Description of test conditions / test construction:

UPS runs in normal mode, applying 100 % non-linear load to the UPS output, then measure output voltage and its fundamental and harmonic components.

Load (%)	Harmonic No.	Phase 1 (dB)	Phase 2 (dB)	Phase 3 (dB)	-
100	3	2.9	/	/	-
100	5	2.9	/	/	-
100	7	2.9	/	/	-
100	9	2.9	/	/	-

THD	Distortion at phase 1	Distortion at phase 2	Distortion at phase 3	Expected value due to the specification of the manufacturer	-
see formula to THD below	2.9%	/	/	≤5%	-

$$THD = 100 \cdot \sqrt{\left(10^{\frac{3^\circ}{20}}\right)^2 + \left(10^{\frac{5^\circ}{20}}\right)^2 + \left(10^{\frac{7^\circ}{20}}\right)^2 + \left(10^{\frac{9^\circ}{20}}\right)^2}$$




IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

6.4.3.2	TABLE: - Output – Non-linear load: Stored energy mode – Full load - Harmonic components measurement				P
Description of test conditions / test construction: UPS runs in battery mode, applying 100 % non-linear load to the UPS output, then measure output voltage and its fundamental and harmonic components.					
Load (%)	Harmonic No.	Phase 1 (dB)	Phase 2 (dB)	Phase 3 (dB)	-
100	3	3.0	/	/	-
100	5	3.0	/	/	-
100	7	3.0	/	/	-
100	9	2.9	/	/	-
THD	Distortion at phase 1	Distortion at phase 2	Distortion at phase 3	Expected value due to the specification of the manufacturer	-
see formula to THD below	3.0%	/	/	≤5%	-
$THD = 100 \cdot \sqrt{\left(\frac{3^{\circ}}{10^{\frac{20}{10}}}\right)^2 + \left(\frac{5^{\circ}}{10^{\frac{20}{10}}}\right)^2 + \left(\frac{7^{\circ}}{10^{\frac{20}{10}}}\right)^2 + \left(\frac{9^{\circ}}{10^{\frac{20}{10}}}\right)^2}$					
					


IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

6.4.3.3.1 6.4.3.3.2	TABLE: - Reference non-linear load – Normal to stored energy mode - AC input failure test - Reference non-linear load – Stored energy to normal mode		P
------------------------	--	--	---

Measured graph:
Before waveform



After waveform



Channel 2 - Output Voltage
Channel 3 - Output Current

Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50Hz	Normal to Battery	219.5	/	/	218.1	/	/	0.6%	/	/


IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

6.4.3.3.2	TABLE: - Reference non-linear load – Stored energy to normal mode		
-----------	--	--	--


Description of test conditions / test construction:

- 1) UPS initially operating at full non-linear load in battery mode, the input supply shall be recovery, then UPS transfers to normal mode,
- 2) Check the system when the utility response normal operation. Measure the transient output voltage deviation.

Measured graph:
Before waveform



After waveform



Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/ 50Hz	Battery to Normal	219.6	/	/	218.9	/	/	0.3%	/	/

Channel 2 - Output Voltage
Channel 3 - Output Current

6.4.3.3.3.a	TABLE: - Reference non-linear load steps – Normal mode ≤ 4.0 kVA rating		N/A
-------------	--	--	-----

Description of test conditions / test construction:

Measured graph:

6.4.3.3.3.b	TABLE: - Reference non-linear load steps – Normal mode > 4.0 kVA rating		
-------------	---	--	--

IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict


Description of test conditions / test construction:

- 1) Impact linear load as defined 33 %=> 66%=100 %=> 66 %=> 33% non-linear load with 230V/50Hz in normal mode.
- 2) Check the transient response.


Measured graph:

- 1) Step load from 33% up to 66% non-linear load

Before waveform



After waveform





Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50Hz	33%=>66% load	220.2	/	/	213.3	/	/	3.1%	/	/

- 2) Step load from 66% up to 100% non-linear load

Before waveform

IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

After waveform




Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50Hz	66%=100% load	219.8	/	/	212.2	/	/	3.5%	/	/


IEC 62040-3

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

3) Step load from 100% down to 66% non-linear load
Before waveform




After waveform



Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50Hz	100%=66% load	220.4	/	/	220.5	/	/	0.1%	/	/


4) Step load from 66% down to 33% non-linear load
Before waveform



IEC 62040-3

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

After waveform



Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/ 50Hz	66%=33 % load	219.9			221.0			0.5%		

Channel 2 - Output Voltage

Channel 3 - Output Current


6.4.3.3.4	TABLE: - Reference non-linear load steps – Stored energy mode ≤ 4.0 kVA rating	N/A
Description of test conditions / test construction: test repeated according to sub-clause 6.4.3.3.3.a		
Measured graph: N/A		

6.4.3.3.4	TABLE: - Reference non-linear load steps – Stored energy mode > 4.0 kVA rating	
Description of test conditions / test construction: test repeated according to sub-clause 6.4.3.3.3.b		
1) Impact linear load as defined 33 %=> 66%=100 %=> 66 %=> 33% non-linear load with 230V/50Hz in battery mode.		
2) Check the transient response		
Measured graph:		
1) Step load from 33% up to 66% non-linear load		


IEC 62040-3

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

Before waveform




After waveform



Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50Hz	33%=66% load	220.3	/	/	211.4	/	/	4.1%	/	/


2) Step load from 66% up to 100% non-linear load

Before waveform




After waveform

IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict




Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50Hz	66%=100% load	219.8	/	/	210.2	/	/	4.4%	/	/

3) Step load from 100% down to 66% non-linear load
Before waveform



After waveform




Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C

IEC 62040-3										
Clause	Requirement + Test						Result - Remark		Verdict	


230V/50Hz	100%=66% load	219.6	/	/	220.7	/	/	0.5%	/	/
-----------	---------------	-------	---	---	-------	---	---	------	---	---

4) Step load from 66% downto 33% non-linear load

Before waveform



After waveform



Power Type	Response procedure	Before			After			deviation < 5%		
		A	B	C	A	B	C	deviation Phase A	deviation Phase B	deviation Phase C
230V/50Hz	100%=66% load	220.1	/	/	221.0	/	/	0.4%	/	/

Channel 2 - Output Voltage

Channel 3 - Output Current

IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

4.5	TABLE: List of critical components					P
Object/part no.	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity ¹ .	
DC fan	YATE LOON ELECTRONICS CO., LTD.	D12BH-12D	12V,0.30A	UL507	UL E189702	
FUSE	ZHEJIANG MINGRONG ELECTRICAL PROTECTION CO.,LTD.	RS15	500V,32A	IEC/EN60127	VDE	
RELAY	SONGCHUAN	832A-1C-F-C 735-2C-C	12VDC,30A,250 V 12VDC,2C,25A,2 50VAC	UL508 & 873	UL E88991 VDE 6615	
Primary wire	FENG CHING METAL CORP	2UEW	130oC	UL 1446	UL	
PCB	various	FR-1 FR-4	130°C, V-0	UL95	UL	
Front panel	CHIMEI	PA765A	Thickness> 2.54mm	UL94	UL	
X2 Cap	XIAMEN FARATRONIC CO.,LTD. SHENZHEN SURONG CAPACITORS CO.,LTD.	MPX/MKP	2.2uF,275V 3.3uF,280V	IEC/EN60384	VDE	
Y Cap	FENGHUA ADVANCED TECHNOLOGY HOLDING CO.,LTD.	CT7	Y2,0.01uF,250V Y2,4700pF,250V	IEC/EN60384	VDE	
Battery	LEOCH BATTERY CO., LTD.	DJW12-7.0 DJW12-9.0	192V,7AH 192V,9AH	UL1989	UL MH26866	
Whole unit						
Breaker	KUOYUH W L ENTERPRISE CO LTD	88	8A/250VAC	UL1077	UL E155159(S)	
ON MAIN board						
Fuses	LITTELFUSE	0216008	F8AL, 250V	EN60127- 1 EN 60127-2	VDE: 40013834	
PCB	BAOYUEJIA ELECTRONICS CO., LTD	BY-2	V-0, 130°C, min. 1.5mm	UL74 UL 796	UL: E230225	

IEC 62040-3					
Clause	Requirement + Test		Result - Remark		Verdict
Mains Transformer	JEPULS TECHNOLOGY(SHENZHEN) CO.,LTD ALT-SHENZHEN FERROCOIL ELECTRONICS TECHNOLOGY CO.,LTD ALT-ShenZhenJiaMei Rui ELECTRONICS CO.,LTD		Class B	IEC 62040	Test with appliance
ON I/P_EMI board					
X-Capacitors	Xiamen Faratronic Co., Ltd	MKP62	X2, 275VAC, 2.2uF, 100°C	IEC 60384-14	VDE: 40000358
Y-Capacitors	GUANGDONG FENGHUA BANGKE ELECTRONIC CO., LTD	CT7-Y2	Y2, 4700pF, 250V, 85oC	IEC 60384-14	VDE: 40013869
MOV/Surge suppressor,/M CB ifused	Nanjing Kemin Electronics Co., Ltd	HEL 20D561K	AC350/DC460	IEC 61051-1 IEC 61051-2	VDE: 40008621
Supplementary information: An asterisk indicates a mark that assures the agreed level of surveillance.					

IEC 62040-3			
Clause	Requirement + Test	Result - Remark	Verdict

Pictures



Fig. 1 –Overview I



Fig. 2 –Overview II

Pictures



Fig. 3 –internal view



Fig. 4 – internal view

Pictures



Fig. 5 – PCB components view



Fig. 6 – PCB trace view

Pictures



Fig. 7 – PCB components view




Fig. 8 – PCB trace view

Pictures




Fig. 9 – PCB components view



Fig. 10 – PCB trace view

Pictures




Fig. 11 – PCB components view




Fig. 12 – PCB trace view

Pictures




Fig. 13 – PCB components view




Fig. 14 – PCB trace view

Pictures




Fig. 15 – PCB component view




Fig. 16 – PCB trace view

Pictures



Fig. 17 – PCB components view




Fig. 18 – PCB trace view